



REFER TO SCWSD ADDENDA

GENERAL NOTES:

1. METER PIT LOCATIONS SHALL BE APPROVED BY THE DISTRICT PRIOR TO INSTALLATION. METER PITS SHALL NOT BE LOCATED IN AREAS SUBJECT TO TRAFFIC OF PEDESTRIAN WALKWAYS WITHOUT DISTRICT APPROVAL.
2. NO LANDSCAPING (TREES, SHRUBS, BOULDERS, ETC.) IS TO BE WITHIN 5 FEET OF METER PIT.
3. GROUND SURROUNDING METER PIT SHALL SLOPE AWAY FROM LID.
4. NO PLUMBING CONNECTIONS ARE TO BE MADE IN METER PIT OR BEFORE THE CURB STOP.
5. LAWN SPRINKLER CONNECTIONS ARE TO BE AT LEAST 5 FEET FROM METER PIT ON THE OUTLET SIDE (BEYOND THE CURB STOP).
7. MAIN VALVES AND METER SHUTOFF VALVES TO BE OPERATED BY DISTRICT PERSONNEL ONLY.

TYPICAL METER PIT WITH PRV INSTALLATION



SPRING CANYON WATER AND SANITATION DISTRICT
Office (970) 226-5605 Operations (970) 218-0199

APPROVED:
DATE: 8/16/2019

SCALE: NTS